

VOC Content Test Certificate

Friday October 19th, 2007

Manufacturer: Davco Construction Materials Pty Ltd

67 Elizabeth Street

Wetherill Park NSW 2164

Sample Description: Lanko 124 Ultraprime acrylic primer

Date Tested: October 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Lanko 124 Ultraprime
Sub-Floor Adhesive 50 grams per Litre	<1 grams per Litre



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0710-08